



Minutes
BUILDING CODE ADVISORY COMMITTEE
CITY AND BOROUGH OF JUNEAU
COMMITTEE MEETING

July 10, 2019
5:00 PM
Juneau Fire Station

I. Roll Call

Committee members present: Doug Murray, Armando DeGuzman, Pat Gorman, and Alan Wilson.

CBJ staff present: Charlie Ford

Others present. None

II. Approval of Minutes

Minutes from 5/22/2019 meeting approved.

III. Public Participation of Non-Agenda Items

None

IV. Completed Action Items

Armando continues with 2015 IBC Architectural review:

Chapter 10 thru 1014.8

Mostly minor rewording and modifications.

Pat begins 2017 NEC review:

100 – Definitions; General; Change 600V to 1000V throughout.

CMP – code making panel used for illustration exhibits.

Lot of minor rewording.

19.08.100(1) – Abandoned – Keep?

110.16(B) – Arc-flash labels required in non-dwellings over 12000 A – Sig Change.

19.08.210.5 – Identification for Branch Circuits – Keep

19.08.210(B) – Ground Fault Circuit Protection – Other Than Dwelling Units – Added crawlspaces and Basements – Sig. Change

19.08.210.11(C) – Branch circuits required; dwelling units – Keep

19.08.215.12 – Identification for feeders – Keep

19.08.225.26 – Outside branch circuits and feeders; vegetation as support – Keep

19.08.225.32 – Outside branch circuits and feeders; location – Keep

19.08.230.24(A) – Overhead service drop conductors; clearances; above roofs – Keep

19.08.230.28(C) – Overhead service drop conductors; masts as supports – Keep

19.08.230.70(A)(1) – Service equipment – disconnecting means; general; readily accessible location – Keep

300.22(B) – New exception for listed wiring in ducts.

Charlie checked with SFM on 19.03.806.1 – still current

Charlie checked with SFM on 19.03.907.2.11 – still current

Progress on 2015 Code Review:

- Doug completed review of the 2015 Uniform Plumbing Code
- Charlie completed review of the 2015 IPMC
- Charlie completed review of 2015 IEBC
- Pat completed review of 2014 NEC
- Armando completed review of 2015 IBC thru 426
- Chris completed review of 2015 IBC Chapters 16, 17, 18, 19, 20, 21, 22, 23, and 24
- Armando completed Chapters 5,6,7,and 8 of the 2015 IBC
- Doug completed review of 2015 IMC
- Chris completed Chapter 22 of 2015 IBC.
- Doug completed review 2015 IFGC.
- Armando completed Chapter 9 of the 2015 IBC
- Armando completed thru Chapter 1014.8
- Pat completed the 2017 NEC thru 314.5

V. Remaining Action Items

- Armando to continue review of 2015 IBC Architectural
- Chris to continue review 2015 IBC Structural
- Pat to review 2017 NEC
- Armando to review Title 19 thru 426 of the 2015 IBC
- Dan to begin review of 2015 IFC
- Chris – Action Item - 1609.1.1 and 1609.1.1.1 – Check on citations
- IMC 601.5 #6 not sure who
- Doug to review 19.07.Table 10A

VI. New Action Items

None

VII. Old Business

None

VIII. New Business

None

IX. Schedule for Next Committee Meeting

- TBD

- **Adjournment**

5:55 PM