



Minutes
BUILDING CODE ADVISORY COMMITTEE
CITY AND BOROUGH OF JUNEAU
COMMITTEE MEETING

May 22, 2019
5:00 PM
Juneau Fire Station

I. Roll Call

Committee members present: Doug Murray, Armando DeGuzman, Pat Gorman, and Alan Wilson.

CBJ staff present: Charlie Ford

Others present: None

II. Approval of Minutes

Minutes from 5/1/2019 meeting approved.

III. Public Participation of Non-Agenda Items

None

IV. Completed Action Items

Armando continues with 2015 IBC review

Chapter 8 – Interior Finishes

Mostly minor rewording.

19.03.806.1 – Action Item Charlie to verify the 2018 SFM version is still viable.

Chapter 9 – Fire Protection Systems

Mostly minor rewording and modifications.

19.03.903.2.3 – Automatic sprinkler systems; Group E – Keep (SFM)

19.03.903.2.8 – Automatic sprinkler systems; Group R – Keep (SFM)

19.03.903.2.8.1 – Automatic sprinkler systems; Group R-1 – Keep (SFM)

19.03.903.8.2 – Automatic sprinkler systems; Group R-2 – Keep (SFM)

19.03.903.8.3 – Automatic sprinkler systems; Group R-4 – Keep (SFM)

19.03.903.2.11.1 - Automatic sprinkler systems; specific building areas and hazards; stories without openings – Keep

19.03.903.2.11.3 - Automatic sprinkler systems; buildings over 3 stories or more than 35 feet in height – Keep

19.03.903.3.1.1.2 - Automatic sprinkler systems; elevator hoistways and machine rooms – Keep (SFM)

19.03.903.1.1.3 - Automatic sprinkler systems; inspectors test valve -

19.03.903.3.6 – Automatic sprinkler systems; Hose threads – Keep (SFM)

19.03.903.6 – Automatic sprinkler systems; existing buildings; Group E – Keep

19.03.904.1 – Alternative automatic fire extinguishing systems; general – Keep

19.03.904.6 – Alternative automatic fire extinguishing systems; dry-chemical systems – Keep

904.11.1 thru 904.11.3 – New sections dealing with Automatic water mist systems.

19.03.904.12 – Alternative automatic fire extinguishing systems; water mist systems – Delete from T19

19.03.906.1 – Portable fire extinguishers; where required – Keep (SFM)

19.03.907.2.3 – Fire alarm and detection systems; Group E – Keep

19.03.907.2.11 - Fire alarm and detection systems; single and multiple station smoke alarms – Keep
 19.03.907.2.11.1 - Fire alarm and detection systems; single and multiple station smoke alarms; Group R-1
 - Keep
 19.03.907.2.11.2 - Fire alarm and detection systems; single and multiple station smoke alarms; Groups
 R-2, R-3, R-4 and I-1 – Keep
 19.03.907.2.11.3 - Fire alarm and detection systems; interconnection – Change section number to
 19.03.907.2.11.5 – Keep
 19.03.907.7.2 - Fire alarm and detection systems; record of completion – Keep
 19.03.909.18 – Smoke control systems; acceptance tests – Keep
 19.03.910.1 – Smoke and heat vents; general – Change section number to 19.03.910.2 – Change title to
 Smoke and heat removal; where required and exception number to exception three – Keep
 915 – Carbon Monoxide Detection – New section – Sig. Change

Progress on 2015 Code Review:

- Doug completed review of the 2015 Uniform Plumbing Code
- Charlie completed review of the 2015 IPMC
- Charlie completed review of 2015 IEBC
- Pat completed review of 2014 NEC
- Armando completed review of 2015 IBC thru 426
- Chris completed review of 2015 IBC Chapters 16, 17, 18, 19, 20, 21, 22, 23, and 24
- Armando completed Chapters 5,6,7, and 8 of the 2015 IBC
- Doug completed review of 2015 IMC
- Chris completed Chapter 22 of 2015 IBC.
- Doug completed review 2015 IFGC.
- Armando completed Chapter 9 of the 2015 IBC

V. Remaining Action Items

- Armando to continue review of 2015 IBC Architectural
- Chris to continue review 2015 IBC Structural
- Pat to review 2017 NEC
- Armando to review Title 19 thru 426 of the 2015 IBC
- Dan to begin review of 2015 IFC
- Chris – Action Item - 1609.1.1 and 1609.1.1.1 – Check on citations
- Charlie to check with SFM on 19.03.806.1
- IMC 601.5 #6 not sure who
- Doug to review 19.07.Table 10A

VI. New Action Items

- Charlie to check with SFM on 19.03.907.2.11

VII. Old Business

None

VIII. New Business

None

IX. Schedule for Next Committee Meeting

- TBD

- **Adjournment**

6:20 PM