



Minutes
BUILDING CODE ADVISORY COMMITTEE
CITY AND BOROUGH OF JUNEAU
COMMITTEE MEETING

September 12, 2018

5:00 PM

Juneau Fire Station

I. Roll Call

Committee members present: Doug Murray, Pat Gorman, and Chris Gianotti.
CBJ staff present: Charlie Ford
Others present: None

II. Approval of Minutes

Minutes from 8/8/2018 meeting approved.

III. Public Participation of Non-Agenda Items

None

IV. Completed Action Items

Pat completes review of the 2014 NEC

(Only major changes are noted)

450.10 – Dry Type Transformer Enclosures - New paragraph & exception “Terminal required for grounding and bonding.”

450.11 (B) – New paragraph “Transformer backfeed ok w/ mfg instructions.”

480.3 – New section for battery terminations/connections.

514.3 (C)(D)(E) – New sections dealing with fuel dispensing in boatyards and marinas.

517.18(A) – New wording requiring patient bed receptacles distinctive color and panelboard indication.

517.18(B) – Eight receptacles required at patient bed locations. (formerly 6)

551.71 – Requires 30 amp receptacle w/50 amp receptacle in RV Parks.

T19.8.590.8 (110.35) – Temporary power connections for construction purposes

625.17 – Cords and Cables – Major rewrite and format – added specificity.

625.44 – New section – Electric vehicle supply equipment connection.

680.42(B) – Deleted bonding requirement for above ground self-contained spas and hot tubs.

680.43 – New exception 3 for wiring of dwelling unit spas and hot tubs.

700.8 – New section requiring SPD in all emergency panels.

700.16 – New paragraph requiring lighting at disconnects.

700.19 – New section No multiwire.

705.12(D) – Major rewrite – Ratings and signage.

725.135 – New section – Specificity.

760.135 – New section – Specificity.

770.49 – New section – Bonding requirement for RMC & IMC.

800.49 – New section – Bonding requirement for RMC & IMC.

800.170 – New section – Listed ties

Pat - re-reviewed New Sections 440.7(A)(1), 430.130 and 430.131 - No issues

V. Remaining Action Items

- Armando to continue review of 2015 IBC Architectural
- Chris to review 2015 IBC Structural

VI. New Action Items

- **Guy's Action Item** –Should we keep T19.8.590.8(110.35) – Temp. power connections.
- **Charlie's Action Item** – Check on Doug's review progress.

VII. Old Business

- **Progress on 2015 Code Review:**
Doug completed review of the 2015 Uniform Plumbing Code
Charlie completed review of the 2015 IPMC
Charlie completed review of 2015 IEBC
Pat completed review of 2014 NEC
Armando reviews 2015 IBC thru 426

VIII. New Business

None

IX. Schedule for Next Committee Meeting

- TBD

- **Adjournment**

6:20 PM