



Minutes
BUILDING CODE ADVISORY COMMITTEE
CITY AND BOROUGH OF JUNEAU
COMMITTEE MEETING

October 18, 2017

5:00 PM

Juneau Fire Station

I. Roll Call

Committee members present: Doug Murray, Joann Lott, Chris Gianotti., Pat Gorman
CBJ staff present: Charlie Ford
Others present. None

II. Approval of Minutes

Minutes from August 1, 2016 meeting – Approved.

III. Public Participation of Non-Agenda Items

None

IV. Completed Action Items

None

V. Remaining Action Items

VI. New Action Items

- Pat to begin review of 2014 NEC
- Doug to begin review of 2015 UPC
- Charlie to begin review of 2015 IPMC
- Charlie to begin review of 2015 IEBC

VII. Old Business

- **Progress on 2012 Code Review:**
- Assembly adopted 2012 Title 19 June, 5, 2017– Became effective July 6, 2016
- CBJ Commission on Sustainability – IECC Adoption. – Coordinate a date for joint meeting with JCOS.

VIII. New Business

- Discussion on thermal standard modification – exterior walls.
Charlie presented Code Modification allowing a minimum R-23 stud bay insulation
As an acceptable option to the R-19 stud bay insulation + R-5 continuous insulation requirement in the 2012 International Residential Code. The Committee approved with a mention that JCOS may have a different opinion once we meet with them to discuss the adoption of the IECC.

IX. Schedule for Next Committee Meeting

- TBD

- **Adjournment**

5:25 PM